



**FIELD AND EASEMENT
OR SIDE OF ROAD
LOCATION**

NOTES:

1. Concrete to be minimum 3,000 PSI @ 28 days.



Department of Utilities
10455 Armstrong Street
Fairfax, VA 22030-3630

CITY of FAIRFAX
USE WITH THE FAIRFAX STANDARD SPECIFICATIONS ONLY

Voice (703) 385-7920
FAX (703) 934-8427
www.fairfaxva.gov

**VALVE BOX STABILIZING
PAD DETAILS**

SCALE:
Not To Scale

REVISION DATE:
July, 2005

DETAIL #
2513.05

SHEET #:
1 of 1